



Level 1 Validation Certificate

This document verifies that the Level 1 Validation process was completed. The session details and audit review outcomes are included here.

This certificate is required for submission – alongside the Level 1 validated water audit software file – to the California Department of Water Resources.

Call Date: 8/3/2020

Water Supplier

Supplier Name:
Laguna Beach County Water
District

Supplier Participants:
David Youngblood

Key Audit Metrics

Data Validity Score:	71	
ILI:	0.92	
Real Loss:	15.15	gal / conn / day
Apparent Loss:	2.48	gal / conn / day
Non-Revenue Water as Percent of Cost of Operating System:	1.4%	

Validator

Validator: Kevin Burgers
Water Systems Optimization

Validator Qualifications: Water Audit Validator Certificate
from the AWWA California Nevada
Section

Certification Statement by Validator

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. ☒

Level 1 Validation – Water Supplier Confirmation

This document confirms participation in and endorsement of the Level 1 Validation as completed.

This acknowledgement is required for submission – alongside your Level 1 validated water audit software file – to the California Department of Water Resources.

Water Supplier Name: Laguna Beach County Water District

Water Supplier Public Water System ID: CA3010017

Water Audit Period: 1/2019 – 12/2019

Water Audit & Water Loss Improvement Steps

Steps taken in the audit period timeframe to increase data source accuracy, reduce real losses, and/or reduce apparent losses, as informed by the water audit.

Recently installed AMI system is being closely monitoring to identify systems leaks as quickly as possible. Any accounts showing continually use are contacted directly to inform the customer in case of on site leaks. Reservoir cleaning has been optimized to use less water. System flushing has been minimized to what is absolutely necessary for water quality.

Certification Statement by Water Supplier Executive:

This water loss audit report meets the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34 and has been prepared in accordance with the method adopted by the American Water Works Association, as contained in their manual, *Water Audits and Loss Control Programs, Manual M36, Fourth Edition* and in the Free Water Audit Software version 5.

Executive Name (print): David Youngblood, PE

Executive Position: Manager of Engineering & Operations

Signature:



Date: August 14, 2020